

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: 001-A
 Facility: City of Blytheville West
 Address: P.O. Box 1784
 City: Blytheville State: AR Zip: 72315
 Contact: Thomas Jones Phone: (870) 763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
3/25/15	NH4-N 7Day		9.4	5.0
3/10/15	Geo Fecal 7Day		2228	2000
Monthly	NH4-N 30-Day		7.7	3.0
Monthly	NH4-N 15	77.5		38.0

We feel this problem was due to:

Extreme winter conditions (8+ inches of snow melt off + excessive rainfall)
washout of plant

We plan on correcting the problem in this manner:

rebuild of solids + regain nitrification

Time estimated that it will take to correct problem:

depending on rainfall + temp within a month (plant is trying to turn around)

Sincerely,




 Authorized Signature

4/21/15

 Date

Blytheville Wastewater Department
P.O. Box 1784
Blytheville, AR.
72315



**RETURN RECEIPT
REQUESTED**

ADEO
NPDES Enforcement
5301 North Shore Drive
North Little Rock, AR.
72118-5317

