

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: 001-A

Facility: City of Blytheville - West WWTF

Address: 4951 N.C.R. 635

City: Blytheville State: AR Zip: 72315

Contact: Thomas Jones Phone: (870) 763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>4/2015</u>	<u>NH3-N</u>		<u>9.8</u>	<u>5</u>
<u>4/2015</u>	<u>Fecal Coliform</u>		<u>832</u>	<u>400</u>

We feel this problem was due to:

Low Solid Concentration in Aeration Basin + Excessive Flow

We plan on correcting the problem in this manner:

Increase Solid Concentration in Aeration Basin + restart nitrification process

Time estimated that it will take to correct problem:

Solids are growing in Aeration Basin + Concentration of NH3-N are going down

Sincerely,

  
\_\_\_\_\_  
Authorized Signature

05-19-2015  
\_\_\_\_\_  
Date



# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: 001-A

Facility: City of Blytheville - West WWTF

Address: 4951 N.C.R. 635

City: Blytheville State: AR Zip: 72315

Contact: Thomas Jones Phone: (870) 763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
4/2015	NH3-N		9.8	5
4/2015	Fecal Coliform		832	400

We feel this problem was due to:

Low Solid Concentration in Aeration Basin + Excessive Flow

We plan on correcting the problem in this manner:

Increase Solid Concentration in Aeration Basin + restart nitrification process

Time estimated that it will take to correct problem:

Solids are growing in Aeration Basin + Concentration of NH3-N are going down

Sincerely,

  
Authorized Signature

05-19-2015  
Date

