

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: 001-A

Facility: Blytheville West WWTF

Address: PO Box 1784

City: Blytheville State: AR Zip: 72315

Contact: Thomas Jones Phone: (870) 763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
01-21-15	Mercury	0.00045		0.00041
01-21-15	Mercury		0.126	0.0657

We feel this problem was due to:

Changing of UV Lamps + a couple were broke during process

We plan on correcting the problem in this manner:

Being more careful + SSR Ellers Engineering Firm already working on a Mercury removal process

Time estimated that it will take to correct problem:

Sincerely,

  
Authorized Signature

02-19-15  
Date

WEST PLANT

Sanitary Sewer Overflow Monthly Report

Facility Name: Blytheville wastewater Permit Number: AR0022560 Reporting Period(Month/Year): JAN. 2015

No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions				
Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease		EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	OEHC-Observed or Evidence of Human Contact	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease	EFK-Evidence of Fish Kill	HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location
<u>701 MEURIE ST.</u>	<u>3-1</u>	<u>1-22-15</u>	<u>1-22-15</u>	<u>50</u>	<u>G/LP</u>	<u>NEAH</u>	<u>H.C/W.O.</u>	<u>GR/DR</u>
<u>701 N. 11TH ST.</u>	<u>C.O.</u>	<u>1-23-15</u>	<u>1-23-15</u>	<u>75</u>	<u>R/C.O.</u>	<u>NEAH</u>	<u>H.C/W.O.</u>	<u>DR/DR</u>

[Handwritten Signature]



2-1-15

Signature of Cognizant or Ranking Official Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

CERTIFIED MAIL™

Blytheville  
P.O. Box 178  
Blytheville, Ar. 72315



RETURN RECEIPT  
REQUESTED

ADEO  
NPDES Enforcement  
5301 North Shore Drive  
North Little Rock, AR.  
72118-5317