

West PLANT

### Sanitary Sewer Overflow Monthly Report

Facility Name: Slytheville Wastewater Permit Number: AP0022560 Reporting Period (Month/Year): July 2015

No Sanitary Sewer Overflows This Monitoring Period

**Summary Report Code Descriptions**

Cause(s) of SSO		SSO Impact	Action(s) Taken	Ultimate Discharge Location
CO-Construction	D-Debris	NEAH-No Evidence of Adverse Health or Environmental Impact	WO-Work Order	CR-Creek/Stream/River (please specify)
E-Equipment Failure	G-Grease	OEHC-Observed or Evidence of Human Contact	EC-Environmental Cleanup	DI-Ditch
HC-Hydro Clean	LF-Line Failure/Break	EFK-Evidence of Fish Kill	HC-Hydro Cleaned	DR-Drop Inlet
R-Rainfall	RG-Roots & Grease		HR-Hand Rodded	GR-Ground Surface
RO-Roots	V-Vandalism		EN-Referred to Engineering	PA-Paved Area
			PN-Public Notification	CB-Contained in Building

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in gallons)	Cause of SSO	Environmental Impact	Action (s) Taken to Address SSO	Ultimate Discharge Location



08/20/2015  
Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: 001-R  
Facility: City of Blytheville - West WWTF  
Address: 4951 N.C.R. 635  
City: Blytheville State: AR Zip: 72315  
Contact: Thomas Jones Phone: (870) 763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
07-01-2015	NH3-N 7 Day		8.3 mg/L	5.0 mg/L
07-2015	NH3-N Monthly		4.2 mg/L	2.8 mg/L

We feel this problem was due to:

Low Concentration of Solids in Aeration Basin

We plan on correcting the problem in this manner:

Rebuilding Solid Concentration in Aeration Basin

Time estimated that it will take to correct problem:

At this time Solid Concentration in Aeration Basin is starting to climb and Ammonia is starting to decrease

Sincerely,

  
Authorized Signature

08-20-2015  
Date