


NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118



RE: NPDES Permit No: AR0022540 Discharge Number: 001-A
Facility: Blytheville, City of - West WWTF
Address: 4951 NCR 635
City: Blytheville State: AR Zip: 72315
Contact: Thomas Jones Phone: (870) 763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
4-25-16	Mercury		0.0971	0.0657

We feel this problem was due to:
poor sample collection / field blank came back high

We plan on correcting the problem in this manner:
re demonstrate sampling procedures

Time estimated that it will take to correct problem:
Immediately


Sincerely,


Authorized Signature

05/23/2016
Date

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118



RE: NPDES Permit No: AR 0022560 Discharge Number: 001-A
 Facility: Blytheville City of - West WWTF
 Address: 4951 NCR C35
 City: Blytheville State: AR Zip: 72315
 Contact: Thomas Jones Phone: (870) 763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
2-2016	Mercury	NA	NA	0.657 ug/L

We feel this problem was due to:
Broken sample bottle in transit to Waypoint Analytical or Mercury done

We plan on correcting the problem in this manner:
Packaging better and earlier sample collection

Time estimated that it will take to correct problem:
~~30~~ Immediately

Sincerely,



 Authorized Signature

3/15/2016

 Date