

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR 0022560 Discharge Number: 001-A

Facility: City of Blytheville West WWTF

Address: 4951 NCR 635

City: Blytheville 1 State: AR Zip: 72315

Contact: Thomas Jones Phone: (870) 763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>8-19-2015</u>	<u>113-IV</u>		<u>8.7</u>	<u>5.0</u>

We feel this problem was due to:

Low Concentration of Solids

We plan on correcting the problem in this manner:

Restarted plant + made site visit in industry

Time estimated that it will take to correct problem:

Came back into compliance 08-24-2015

Sincerely,


Authorized Signature

09-24-2015
Date