

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0022560 Discharge Number: #001

Facility: West Treatment Plant

Address: 4951 NCR 635

City: Blytheville State: AR Zip: 72315

Contact: Thomas Jones Phone: (870) 763-4961

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
<u>09/24/14</u>	<u>NH3-N</u>		<u>7.6 mg/L</u>	<u>5 mg/L</u>

We feel this problem was due to:

Low solids concentration in
eration basin

We plan on correcting the problem in this manner:

This was a continuance
from the prior month.
We seeded the plant.

Time estimated that it will take to correct problem:

Problem has been
corrected as of this date.

Sincerely,




Authorized Signature

09/20/14

Date

CERTIFIED MAIL™



7011 2970 0002 5564 4065



1000

72118

U.S. POSTAGE
PAID
BLYTHEVILLE, AR
72315
OCT 22, 14
AMOUNT

\$7.61

00079857-06

Blytheville Waste Water Dept.
P.O. Box 1784
Blytheville, AR.
72315

ADEO
NPDES Enforcement
3301 North Shore Drive
North Little Rock, AR.

72118-5317

RETURN RECEIPT
REQUESTED

