

870-239-7700 Fax: 870-239-7798 www.paragould.com

May 10, 2016

Arkansas Department of Environmental Quality NPDES Enforcement Section 5301 Northshore Drive North Little Rock, AR 72118-5317

Re:

NPDES Permit # AR0033766 - Paragould Light Water & Cable (PLWC)

April 2016 Permit Violation

To Whom It May Concern:

I regret to inform you that the wastewater treatment plant was in non-compliance during the month of April 2016. The non-compliance was for the TSS weekly average limit. We determined the cause of the violation was due to bringing diverted wastewater into the plant for treatment. See the attached non-compliance report for more details.

If you have any questions or comments, please call Lisa Ellington, Manager of Environmental Services, at (870) 239-7795. Thank you.

Sincerely, Cornell Phillips

Darrell Phillips

General Manager/CEO

PERMITTEE PERMIT NO.	Paragoul AR0033	d Light, Water and Cable - Wastewater Treatment Plant 766
DATE OF VIOLATION		Week of April 4, 2016
PARAMETER VIOLATED		TSS Weekly Average
REPORTED DISC	HARGE	TSS Weekly Average: 25.2 ppm
PERMIT CONDITION		TSS Weekly Average: 22.5 ppm
receiving waters:		lying discharge including its impact upon the DES permit limit; there were no observable impacts to the
Cause of the non-co	mnliance	
		ue to bringing diverted wastewater into the plant for
treatment.	occurred di	de to bringing diverted wastewater into the plant for
Anticipated time the if it has been correct At the present time,	ted, the du	n of noncompliance is expected to continue or, aration of the period of noncompliance: in compliance.
Steps taken to reduce PLWC will closely number increasing.	ce or eliminonitor dive	nate the noncomplying discharge: erted flows into the plant to keep TSS levels from
Steps taken to preve Operators will closel	ent recurre y monitor f	ence of the condition of noncompliance: flows and solids concentrations.
5-10-20	16	Darrell Phillips

Signature

Date