

ADEQ

ARKANSAS
Department of Environmental Quality

October 30, 2014

Lisa Ellington
Paragould Light, Water, and Cable
Wastewater Treatment Plant
P.O. Box 9
Paragould, AR 72450

RE: NPDES Permit No. AR0033766, AFIN 28-00060, Effluent Violations

Dear Ms. Ellington:

A review of the NPDES file Paragould Light, Water, and Cable, Wastewater Treatment Plant for the period of December 1, 2013 thru September 30, 2014 revealed the following compliance issue:

The facility reported 3 violations of Part I, Section A. of NPDES Permit No.: AR0033766. The effluent violations reported are as follows:

DMR End Date	Discharge	Parameter	Reported Value	Permit Limit
12/31/13	001C	Chlorine, total residual (INST MAX, mg/L)	.21	.1
04/30/14	001C	Chlorine, total residual (INST MAX, mg/L)	.16	.1
09/30/14	001C	Chlorine, total residual (INST MAX, mg/L)	.39	.1

The Department expects Paragould Light, Water, and Cable to continue to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0635, or you may e-mail me at anderson@adeq.state.ar.us.

Sincerely,



Alan Anderson
Enforcement Analyst
Water Division / Enforcement Branch

