

## Anderson, Alan

---

**From:** Lisa Ellington <lellington@paragould.com>  
**Sent:** Friday, May 29, 2015 2:40 PM  
**To:** Anderson, Alan  
**Subject:** RE: Permit renewal

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Good afternoon Alan,

Based on reports, most noncompliances with TRC was due to the equipment not working properly. Currently WWTP operators check chlorine and sulfur dioxide equipment daily to ensure proper operation. Also, the company who installed the equipment has been here several times to work on the system.

Plans are for PLWC to install a UV system during the 4<sup>th</sup> quarter this year. This will eliminate the use of chlorine and sulfur dioxide. Our consulting engineers are in the design phase of the project, and once complete it will be sent to ADEQ for approval. After the system is installed and operational, PLWC will request a permit revision from ADEQ.

Let me know if you need additional information.

Have a great weekend!

Lisa

*Lisa Ellington  
Environmental Services Manager  
Paragould Light, Water & Cable  
P.O. Box 9  
Paragould, AR 72450  
Phone (870) 239-7795  
Fax (870) 239-7791  
[lellington@paragould.com](mailto:lellington@paragould.com)*

---

**From:** Anderson, Alan [<mailto:ANDERSON@adeq.state.ar.us>]  
**Sent:** Friday, May 29, 2015 1:54 PM  
**To:** Lisa Ellington  
**Subject:** Permit renewal

Hi Lisa:

I am working with the Permit Engineer to get the Discharge Permit renewed. I actually did the review a year ago, but am doing a short follow up. so if I could get the following info from you that would be great.

A brief summary of the corrective actions to eliminate the TRC violations:

Thanks

Alan Anderson  
Enforcement Analyst  
ADEQ Water Division  
501-682-0635