Sanitary Sewer Overflow Monthly Report

Facility Name: Paragould Light, Water & Cable - WWTP **Permit Number:** AR0033766 **Reporting Period (Month/Year):** September 2022

☐ No Sanitary Sewer Overflows This Monitoring Period

Summary Report Code Descriptions					
Cause(s) of SSO		SSO Impact	Action(s) Taken		Ultimate Discharge Location
CO - Construction	D - Debris	EFK - Evidence of Fish Kill	DD - Disinfected & Deoderized	EC - Environmental Cleanup	CB - Contained in Building
E - Equipment Failure	G - Grease	NEAH - No Evidence of Adverse Health of Environmental Impact	EN - Referred to Engineering	GN - Generator to Power Equipment	CR - Creek/Stream/River (please specify)
I&I / R - Rainfall	LF - Line Failure/Break	OEEI - Observed or Evidence of Environmental Impact	HC - Hydro Cleaned	HR - Hand Rodded	DI - Ditch
PF - Power Failure	RG - Roots & Grease	OEHC - Observed or Evidence of Human Contact	JV - Jet-Vac	MR - Machine Rodded	DR - Drop Inlet
RO - Roots	V-Vandalism		PN - Public Notification	SL - Spread Lime on Area	GR - Ground Surface
			SR - Check with SL Rat Periodically	WO - Work Order	PA - Paved Area

Location	Manhole #	Start Date of SSO	End Date of SSO	Estimated Volume (in Gallons)	Cause of SSO	Environmental Impact	Action(s) Taken to Address SSO	Ultimate Discharge Location
Carraige Hill Lift Station #39	N/A	09/05/22	09/05/22	500	E - (PLC Reboot and lost all alarms)	NEAH	SL	GR
Goldsmith Lift Station #25	N/A	09/22/22	09/22/22	450	LF	NEAH	SL	GR

Signature of Cognizant or Ranking Official: Bill Bradford - COO

10/12/2022
Date

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisionment for knowing violations."