

Anderson, Alan

From: Lisa Ellington <lellington@paragould.com>
Sent: Friday, March 13, 2015 8:49 AM
To: Anderson, Alan
Cc: Darrell Phillips
Subject: NPDES Permit #AR0033766 - Bypass Event #2

Mr. Anderson,

As required by NPDES Permit #AR0033766 for Paragould Light Water and Cable (PLWC), this serves as notification that the PLWC WWTP facility is currently experiencing an unanticipated bypass from the overflow lagoon due to melting of wintry precipitation and rainfall. This is the second event of the bypass, with the first event beginning March 10, 2015 and ending March 12, 2015.

The bypass in the lagoon began on March 13, 2015 at approximately 2:30 AM, and samples will be taken each day during the bypass event. Once this event stops, we will inform you of the end date and an approximate amount of water discharged. Sample results will be sent you after analysis is complete and data summarized. In addition, we will work to bring down the water level in the lagoon as quickly as possible at the conclusion of this event.

If you have questions or need additional information, please do not hesitate to contact me. Thank you for your assistance in this matter.

*Lisa Ellington
Environmental Services Manager
Paragould Light, Water & Cable
P.O. Box 9
Paragould, AR 72450
Phone (870) 239-7795
Fax (870) 239-7791
lellington@paragould.com*

Anderson, Alan

From: Lisa Ellington <lellington@paragould.com>
Sent: Tuesday, March 17, 2015 1:48 PM
To: Anderson, Alan
Cc: Darrell Phillips
Subject: NPDES Permit #AR0033766 - Bypass Event #2

Follow Up Flag: Follow up
Flag Status: Flagged

Mr. Anderson,

As required by NPDES Permit #AR0033766 for Paragould Light Water and Cable (PLWC), this serves as notification that Event #2 from the unanticipated Bypass ceased March 16, 2015 at approximately 3:00 AM. An estimated 1.1 million gallons were discharged during this event. Samples of the lagoon discharge have been taken, and results will be reported to you as soon as testing is complete.

Currently, lagoon water is being pumped into the plant for treatment, and PLWC will make every effort to prevent another bypass. Unfortunately, forecasts show possible showers beginning tomorrow afternoon and continuing into Thursday morning.

If you have questions or need additional information, please do not hesitate to contact me. Thank you for your assistance in this matter.

*Lisa Ellington
Environmental Services Manager
Paragould Light, Water & Cable
P.O. Box 9
Paragould, AR 72450
Phone (870) 239-7795
Fax (870) 239-7791
lellington@paragould.com*