



August 21, 2018

Monty Ledbetter, Utilities Director
City of Hot Springs
P.O. Box 700
Hot Springs, AR 71902

email: mLedbetter@cityhs.net

**RE: Permit Number: AR0033880, AFIN: 26-00145
Effluent Violations**

Dear Mr. Ledbetter:

A review of the Permit file for the above mentioned facility for the period of April 1, 2018, through June 30, 2018, revealed the following reported violations of the permitted effluent limitations:


The facility has reported **10 effluent violations** of Part I, Section A of Permit No. AR0033880:

DMR End Date	Discharge Number	Parameter Description	Reported DMR Value	Permit Limit	Vio %
4-30-2018	001-A	Solids, total suspended (MO AVG, lb/d)	3050	1500	103%
4-30-2018	001-A	Solids, total suspended (MO AVG, mg/L)	18.2	15	21%
4-30-2018	001-A	Solids, total suspended (7 DA AVG, mg/L)	30.4	22.5	35%
4-30-2018	001-A	BOD, carbonaceous [5 day, 20 C] (MO AVG, lb/d)	1639	1000	64%
4-30-2018	001-A	BOD, carbonaceous [5 day, 20 C] (MO AVG, mg/L)	10.03	10	0%
4-30-2018	001-A	BOD, carbonaceous [5 day, 20 C] (7 DA AVG, mg/L)	20.19	15	35%
5-31-2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, lb/d)	549.2	360.3	52%
5-31-2018	001-A	Nitrogen, ammonia total [as N] (MO AVG, mg/L)	6.9	3.6	92%
5-31-2018	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	10.3	7.5	37%
6-30-2018	001-A	Nitrogen, ammonia total [as N] (7 DA AVG, mg/L)	7.7	7.5	3%

Non-compliance reports were submitted with the Discharge Monitoring Reports. Any violation of your Permit is subject to further enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Thank you for your attention to this matter.

Should you have any questions concerning the above referenced effluent violations, please feel free to contact me at 501-682-0630, or you may e-mail me at allen-daniel@adeq.state.ar.us.

Sincerely,

A handwritten signature in cursive script that reads "Leslie Allen-Daniel".

Leslie Allen-Daniel
Enforcement Analyst
Office of Water Quality

cc: Gordon Yates, Operator (GYates@cityhs.net)