



ARKANSAS
Department of Environmental Quality

May 21, 2014

David Watkins
City Manager, City of Hot Springs
P.O. Box 700
Hot Springs, AR 71902

RE: NPDES Permit Number: AR0033880 AFIN: 26-00145
City of Hot Springs-Regional Wastewater Treatment Plant

Dear Mr. Watkins,

A review of the NPDES file for the above mentioned facility for the month of March 2014 revealed the following effluent violations:

DMR End Date	Dsch#	Parameter	Limit Value	DMR Value
03/31/2014	001-A	Solids, total suspended, MO AVG, lb/d	1500.	1715
03/31/2014	001-A	Solids, total suspended, 7 DA AVG, mg/L	22.5	35.49
03/31/2014	001-A	Phosphorus, total [as P], MO AVG, lb/d	100.1	114

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0630, or you may e-mail me at allen-daniel@adeq.state.ar.us.

Sincerely,

Leslie Allen-Daniel
Enforcement Analyst
Water Division, Enforcement Branch