

# ADEQ

A R K A N S A S  
Department of Environmental Quality

September 11, 2013

Mr. James Sorrells, Facility Manager  
City of Hot Springs WWTP  
320 Davidson Dr.  
Hot Springs, AR 71901

RE: NPDES Permit Number AR0033880                      AFIN 26-00145  
NPDES Permit Effluent Violations

Dear Mr. Sorrells,

A recent review of the above referenced permit has revealed the following permit effluent violations for the monitoring period ending July 31, 2013:

Discharge Number	Parameter	Violation	Limit
001-A	Phosphorus, total MO AVG lb/d	104.1	100.1
001-A	Nitrogen, ammonia, total (as N) 7 DA AVG (mgL)	7.52	7.5

As you know, Arkansas Pollution Control and Ecology Commission regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations. Please note that any violation of your permit can lead to enforcement action by ADEQ pursuant to the Arkansas Water and Air Pollution Control Act. Also, be aware that we maintain records of violations and of non-compliance reports documenting corrective action to determine the appropriateness and level of the enforcement action.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0630 or e-mail at [layher@adeq.state.ar.us](mailto:layher@adeq.state.ar.us).

Sincerely,



April Layher  
Enforcement Analyst  
Water Division, Enforcement Branch