

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033880 Discharge Number: 001A

Facility: Hot Springs City of WWTP

Address: 320 Davidson Dr

City: Hot Springs State: AR Zip: 71901

Contact: James Sorrells Phone: 1-501-262-1125 Ext 10

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
March 2018	TSS	1669		Mo avg 1500 lbs./day
	TSS		40.4mg/l	15 mg/l 22mg/l
	C-bod		22.31 mg/l	10.0mg/l 15.0mg/l
	C-bod	1022		1000 # day Mo avg
	Fecal /	13454.58		1000 Mo / 7day 2000

We fill this problem was due to:

Excessive infiltration from storm events , and the fact that the WWTP is under a construction permit for headworks upgrade and not able to treat as much wastewater through the plant , there going on bypass much earlier and longer than in the past.

We plan on correcting the problem in this manner:  
With construction completion

Time estimated that it will take to correct problem:  
Planned this coming summer

Sincerely,  
James B Sorrells / Gordon Yates

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date 4-23--2018