



CITY OF HOT SPRINGS

Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

SSO ANALYSIS REPORT

Date of overflow event: 4/27/24

Date and time of notification: 4/27/24 @ 0917

Location of event: Gulpha (Manhole 1750)


Sample collection date and time: 4/27/24 @ 1045

Samples analyzed for: E. Coli

ANALYSIS RESULTS

Site 1: E. Coli – 517.2 cfu per 100mls
(Overflow Location)

This test result is below the EPA recommended 630 cfu's per 100mls at designated Site #1. No further testing is required.



Steven Rynders
Laboratory Technician

Harold Mauldin
Facilities Operations Manager
City of Hot Springs