



# CITY OF HOT SPRINGS

## Davidson Wastewater Treatment Plant

320 Davidson Drive Hot Springs, Arkansas 71901

Phone: (501) 621-5041

### SSO ANALYSIS REPORT

Date of overflow event: 4/9/24

Location of event: Gulpha Creek (Manhole 1750)

Sample collection date: 4/22/24

Samples analyzed for: E. Coli

#### ANALYSIS RESULTS

<u>Site #</u>	<u>Time collected</u>	<u>Results</u>
Site 3:	1118	E. Coli – 52.0 cfu per 100m
Site 4:	1121	E. Coli – 22.3 cfu per 100mls
Site 5:	1128	E. Coli – 27.2 cfu per 100mls

On 4/16/24 and 4/19/24 test results were below 630 cfu's at site # 2. On 4/19/24 and 4/22/24 test results were below 630 cfu's at site #3, site #4, and site #5. No further testing is required at this time.

Amanda Cates  
Laboratory Supervisor

Harold Mauldin  
Facilities Operations Manager  
City of Hot Springs