

ADEQ

ARKANSAS
Department of Environmental Quality

December 5, 2017

Hon. Rob Young, Mayor
City of Corning
P.O. Box 538
Corning, AR 72422

RE: NPDES Permit Number AR0033979, AFIN 11-00061
Permitted Effluent Limitation Violations

Dear Mayor. Young,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 14 violations of Part I, Section A of NPDES Permit No. AR0045411 during the review period. A detailed list of the violations has been included with this letter. The Department expects the City of Corning to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

The Department recommends that the City of Corning consult with a professional engineer for the purpose of developing a corrective action plan (CAP) designed to eliminate violations of the effluent limitations of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,



Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio
08/31/2017	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.9	5%
07/31/2017	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.76	12%
06/30/2017	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.61	20%
05/31/2017	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.68	16%
05/31/2017	001-A	BOD, 5-day, 20 deg. C, MO AVG, mg/L	30	30.9	3%
05/31/2017	001-A	BOD, 5-day, 20 deg. C, 7 DA AVG, mg/L	45	64.9	44%
04/30/2017	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.92	4%
11/30/2016	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.6	20%
08/31/2016	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.93	4%
08/31/2015	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.97	2%
06/30/2015	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.79	11%
06/30/2015	001-A	Coliform, fecal general, 30DA GEO, #/100mL	200	236	18%
05/31/2015	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.57	22%
10/31/2014	001-A	Oxygen, dissolved [DO], MO AV MN, mg/L	>=2	1.2	40%