

Gray, Gavin

From: Gray, Gavin
Sent: Friday, December 15, 2017 8:39 AM
To: 'rob.young@centurytel.net'
Subject: missing DMR

RE: NPDES Permit Number AR0033979, AFIN 11-00061

Dear Mayor Young,

The Department is in receipt of the enclosed Discharge Monitoring Report (DMR) for Discharge No. 001-A, monitoring period ending 09/30/2017. Upon review, we have noted that the DMR is defective for the following limited parameters that were not provided:

Monitoring Period End Date	DMR Due Date	Disch-Desig	Parameter Desc	Statistical Base Desc	Permit Limit Value	Limit Unit	DMR Value Received Date
09/30/2017	Oct 25, 2017	001-A	Oxygen, dissolved [DO]	MO AV MN	2	mg/L	
09/30/2017	Oct 25, 2017	001-A	BOD, 5-day, 20 deg. C	MO AVG	222.7	lb/d	
09/30/2017	Oct 25, 2017	001-A	BOD, 5-day, 20 deg. C	MO AVG	30	mg/L	
09/30/2017	Oct 25, 2017	001-A	BOD, 5-day, 20 deg. C	7 DA AVG	45	mg/L	
09/30/2017	Oct 25, 2017	001-A	pH	MINIMUM	6	SU	
09/30/2017	Oct 25, 2017	001-A	pH	MAXIMUM	9	SU	
09/30/2017	Oct 25, 2017	001-A	Solids, total suspended	MO AVG	668	lb/d	
09/30/2017	Oct 25, 2017	001-A	Solids, total suspended	MO AVG	90	mg/L	
09/30/2017	Oct 25, 2017	001-A	Solids, total suspended	7 DA AVG	135	mg/L	
09/30/2017	Oct 25, 2017	001-A	Flow, in conduit or thru treatment plant	MO AVG	Report	MGD	
09/30/2017	Oct 25, 2017	001-A	Flow, in conduit or thru treatment plant	DAILY MX	Report	MGD	
09/30/2017	Oct 25, 2017	001-A	Coliform, fecal general	30DA GEO	200	#/100mL	
09/30/2017	Oct 25, 2017	001-A	Coliform, fecal general	7 DA GEO	400	#/100mL	
09/30/2017	Oct 25, 2017	001-A	Overflows	MO TOTAL	Report	occur/mo	
09/30/2017	Oct 25, 2017	001-A	Overflow volume [SS0 volume, CSO volume]	MO TOTAL	Report	gal	

Submittal of a corrected DMR will be required. Please re-submit the enclosed DMR with the required information. Submit two copies of the DMR clearly marked "Corrected Copy" and keep a third copy for your records or resubmit online at NetDMR. A new signature by the ranking or cognizant official will also be required.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

-
Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0667 or you may e-mail me at gavin.gray@adeq.state.ar.us

Gavin Gray
Enforcement Analyst
Office of Water Quality
Arkansas Department of Environmental Quality
(501) 682-0667