

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
Office of Water Quality – Enforcement Branch
5301 Northshore Drive
North Little Rock, AR 72118

RE: Permit No: AR0033979 Discharge Number: 001-A
Facility: CITY OF CORNING
Address: 1401 CR 128
City: CORNING State: AR Zip: 72422
Contact: Eddie D. Hill Phone: 870-323-2258

Date of Non-Compliance	Parameter Exceeded	Quantity or Loading	Quality or Concentration	Permit Limits
5/17/23	FECAL 7 DAY GEO		630.0	400.0

We feel this problem was due to:

Our pond levels might have went to low and was sucking sludge.

We plan on correcting the problem in this manner:

We will keep a better eye on pond levels to avid this situation.

Time estimated that it will take to correct problem:

1 month

Sincerely,



06/23/2023

Submitted By:

Date

Submitted electronically via NetDMR

Certification Statement: I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (Revised March 2016)