

Gray, Gavin

From: Gray, Gavin
Sent: Friday, February 16, 2018 1:08 PM
To: 'John Selig'
Subject: RE: NPDES Permit # AR0033979, AFIN 11-00061

I have included the requested information.

The reason the Department requested a Cap was the repeated offenses of Dissolved Oxygen

DMR End Date	Discharge Number	Parameter Description	DMR Value Qualifier Code	Reported DMR Value	Permit Limit	Vio %	Violation Type	DMR Value Type Code	Parameter-Mon. Location-Season
10/31/2014	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.2	2	40%	Numeric Vio	C1	00300-1-0
05/31/2015	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.57	2	22%	Numeric Vio	C1	00300-1-0
06/30/2015	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.79	2	11%	Numeric Vio	C1	00300-1-0
06/30/2015	001-A	Coliform, fecal general (30DA GEO, #/100mL)	=	236	200	18%	Numeric Vio	C2	74055-1-0
08/31/2015	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.97	2	2%	Numeric Vio	C1	00300-1-0
08/31/2016	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.93	2	4%	Numeric Vio	C1	00300-1-0
11/30/2016	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.6	2	20%	Numeric Vio	C1	00300-1-0
04/30/2017	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.92	2	4%	Numeric Vio	C1	00300-1-0
05/31/2017	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.68	2	16%	Numeric Vio	C1	00300-1-0
05/31/2017	001-A	BOD, 5-day, 20 deg. C (MO AVG, mg/L)	=	30.9	30	3%	Numeric Vio	C2	00310-1-0
05/31/2017	001-A	BOD, 5-day, 20 deg. C (7 DA AVG, mg/L)	=	64.9	45	44%	Numeric Vio	C3	00310-1-0
06/30/2017	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.61	2	20%	Numeric Vio	C1	00300-1-0
07/31/2017	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.76	2	12%	Numeric Vio	C1	00300-1-0
08/31/2017	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.9	2	5%	Numeric Vio	C1	00300-1-0
09/30/2017	001-A	Oxygen, dissolved [DO] (MO AV MN, mg/L)	=	1.79	2	11%	Numeric Vio	C1	00300-1-0

Gavin Gray
Enforcement Analyst
Office of Water Quality
Arkansas Department of Environmental Quality
(501) 682-0667

From: John Selig [<mailto:jselig@ce-associates.biz>]
Sent: Friday, February 16, 2018 12:28 PM
To: Gray, Gavin
Cc: waterbeau@yahoo.com
Subject: NPDES Permit # AR0033979, AFIN 11-00061

Mr. Gray,

CEA has been contacted by the City of Corning to look at the permit violations for the above-referenced permit number. Can you please email the appropriate DMR information for the time period covering October 31, 2014 – September 30, 2017?

Thank you for your cooperation in this matter. We would like to review this information before we attempt to prepare a CAP for the City.

If you have any questions or need to speak with me about this request, you can reach me on my cell phone at 870-273-4185.

John S. Selig, P.E.
Civil Engineering Associates, LLC
2114 East Matthews Avenue
Jonesboro, Arkansas 72401
(870) 972-5316