

REPORT OF NON COMPLIANCE

NAME OF FACILITY CORNING, CITY OF

PERMIT NUMBER AR0033979 001-A

PERIOD ENDING June 2015

PARAMETER VIOLATED	DO CONC MO AVG MIN	FECAL 30DA GEO					
REPORTED VIOLATIONS	1.79	236.0					
PARAMETER VIOLATED	2.0	200.0					

WEEK OF

Please fill out the following information

CAUSE OF VIOLATION Faulty Pump Control Timer

DURATION OF VIOLATION 3 weeks


CORRECTIVE ACTION Purchased new timer and installed

EXPECTED COMPLIANCE DATE 7-5-2015

[Signature] 7/5/2015
SIGNATURE / DATE

City of Corning
P.O. Box 538
Corning, Ar 72422

MEMPHIS
TN 383
28 OCT '15
PM 11



02 1P \$ 000.70⁵
0004644499 OCT 28 2015
MAILED FROM ZIP CODE 72422

ADEQ
NPDES ENFORCEMENT

5301 Northshore Drive
North Little Rock, AR 72118

72118-591799

