



ARKANSAS

ENERGY & ENVIRONMENT

December 19, 2022

Honorable Flora J Simon, Mayor
City of Dumas
155 E. Waterman
Dumas, AR 71639

Email: dumasarmayor@gmail.com

**RE: NPDES Permit Number: AR0033987, AFIN: 21-00045
Corrective Action Plan Request**

Dear Mayor Simon

A review of the NPDES file for the above mentioned facility for the period of October 1, 2019, through October 31, 2022 reveals the following compliance issues:

The facility has reported **10 effluent violations** of Part I, Section A. of NPDES Permit No. AR0033987:

AR0033987 - DUMAS, CITY OF (21-00045)

DMR End Date	Disch-Desig	Parameter Desc	Reported DMR Value	Limit Value	Vio %	Vio Code
05/31/2020	001-A	Chlorine, total residual (INST MAX, mg/L)	0.31	.028	1,007%	Numeric Vio
12/31/2020	001-A	Chlorine, total residual (INST MAX, mg/L)	0.16	.028	471%	Numeric Vio
03/31/2021	001-A	Chlorine, total residual (INST MAX, mg/L)	0.07	.028	150%	Numeric Vio
08/31/2021	001-A	Chlorine, total residual (INST MAX, mg/L)	0.06	.028	114%	Numeric Vio
12/31/2021	001-A	Chlorine, total residual (INST MAX, mg/L)	0.03	.028	7%	Numeric Vio
03/31/2022	001-A	Chlorine, total residual (INST MAX, mg/L)	0.03	.028	7%	Numeric Vio
08/31/2022	001-A	pH (MAXIMUM, SU)	9.5	9		Numeric Vio
08/31/2022	001-A	Chlorine, total residual (INST MAX, mg/L)	0.4	.028	1,329%	Numeric Vio
09/30/2022	001-A	Chlorine, total residual (INST MAX, mg/L)	0.09	.028	221%	Numeric Vio
10/31/2022	001-A	Chlorine, total residual (INST MAX, mg/L)	0.05	.028	79%	Numeric Vio

Non-compliance Reports (NCRs) were received by the Division, but due to repeat occurrences, DEQ recommends that you consult with a Professional Engineer for the purpose of developing a Corrective Action Plan (CAP). The CAP should detail the corrective actions taken or that will be

taken to achieve compliance with the terms of the effluent limitations of the Permit and include a reasonable milestone schedule. The CAP should also include the date the facility expects to be in compliance. Please submit the CAP to DEQ by February **20, 2023**.

Any violation of your NPDES Permit is subject to enforcement action by this Division, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0056, or you may e-mail me at thomas.harrington@adeq.state.ar.us

Sincerely,

A handwritten signature in blue ink that reads "Thomas Harrington". The signature is written in a cursive style with a long horizontal stroke at the beginning.

Thomas Harrington
Enforcement Analyst, DEQ, OWQ
5301 Northshore Drive, North Little Rock, AR 72118

cc: Patrick Fitzgerald, Manager, pfitz@yahoo.com