



ARKANSAS ENERGY & ENVIRONMENT

March 2, 2023

Honorable Price Boney, Mayor
City of Dumas
P.O. Box 157
Dumas, AR 71639

email: dumasarmayor@gmail.com

**RE: Permit Number: AR0033987, AFIN: 21-00045
Effluent Violation Warning Letter and Request for Non-Compliance Report**

Dear Mayor Boney:

A review of the Permit file for the above mentioned facility for the period of November 1, 2022 through January 31, 2023 revealed the following compliance issues:

The facility has reported **2 effluent violations** of Part I, Section A of Permit No. AR0033987:

DMR End Date	Disch-Desig	Parameter Desc	Reported DMR Value	Limit Value	Vio %	Vio Code
11/30/2022	001-A	Chlorine, total residual (INST MAX, mg/L)	0.14	.028	400%	Numeric Vio
12/31/2022	001-A	Chlorine, total residual (INST MAX, mg/L)	0.14	.028	400%	Numeric Vio

Non-compliance reports with corrective actions were received by the Division for the month of November 2022. The following Non-Compliance Reports (NCRs) is missing and must be submitted by March 7, 2023.

- December 001-A, for Total Residual Chlorine

Any violation of your Permit is subject to further enforcement action by this Division, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0736, or you may e-mail me at thomas.harrington@adeq.state.ar.us.

Sincerely,

Thomas Harrington
Enforcement Analyst, DEQ, OWQ
5301 Northshore Drive, North Little Rock, AR 72118

cc: Patrick Fitzgerald, Water Manager, pfitz2003@yahoo.com

