

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987      Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
December, 2022	Total Residual Chlorine	0.14 mg/L	0.028 mg/l Max limit

We feel this problem was due to:

*Uncertain, however ~~the~~ automatic feeder was not working properly.*

We plan on correcting the problem in this manner:

*Re-calibrated the automatic feeder*

Time estimated that it will take to correct the problem/s:

*As soon as it was adjusted the next day.*

Sincerely,

*Patrick Fitzgerald*  
Authorized Signature

*3-7-23*  
Date