

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

**RE: NPDES Permit No:** AR0033987      **Discharge Number:** A - 001-Monthly

---

**Facility:** The City of Dumas

---

**Address:** 204 Ford Loop Road

---

**City:** Dumas

**State:** AR

**Zip:** 71639

---

**Contact:** Patrick Fitzgerald

**Phone:** 870-382-1143

---

Date of Non-Compliance	Parameter Exceeded	Instantaneous Maximum	Permit Limits
December 31st, 2018	Total Residual Chlorine	0.05 mg/L	.028 mg/L Inst. Maximum

We feel this problem was due to:

---

---

---

We plan on correcting the problem in this manner:

---

---

---

Time estimated that it will take to correct the problem/s:

---

---

---

Sincerely,

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Date