

12/11/2020 MON 11:23 AM

FAX #

P. 102

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
 NPDES Enforcement Section
 5301 Northshore Drive
 North Little Rock, AR 72118

RE: NPDES Permit No: AR0033087 Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Instantaneous Maximum	Permit Limits
December 10th, 2020	Total Residual Chlorine	0.16 mg/L	.028 mg/l Inst. Maximum

We feel this problem was due to:

Sulfur Bottle was Not changed
 Scale was Not set Properly

We plan on correcting the problem in this manner:

Changed the bottle & set scales

Time estimated that it will take to correct the problem/s:

Immediately

Sincerely,

Patrick Fitzgerald

Authorized Signature

1-25-21

Date