

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987 Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas State: AR Zip: 71639

Contact: Patrick Fitzgerald Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
March, 2023	Total Residual Chlorine	0.4 mg/L	0.028 mg/l Max limit

We feel this problem was due to:

UNCERTAIN, everything looked ok

We plan on correcting the problem in this manner:

Adjusting Feeders

Time estimated that it will take to correct the problem/s:

same day

Sincerely,

Patrick Fitzgerald

Authorized Signature

6-16-23

Date