

Record of Communication

Key#: 912 **Date:** 3/24/2017 2:19: **Facility:** City of Dumas

From: Kyle Barber, Office of Water Qual **NPDES #:** AR0033987

To: Patrick Fitzgerald

I asked Mr. Fitzgerald about the TRC exceedance for the monitoring period ending 02/28/2017, and he told me that the problem could be fixed with a minor chlorination adjustment, which should correct the issue immediately.