

July 21, 2020

Honorable Flora J. Simon  
Mayor, City of Dumas  
155 E. Waterman  
Dumas, AR 71639

email: [dumasmayor@gmail.com](mailto:dumasmayor@gmail.com)

RE: NPDES Permit Number AR0033987, AFIN 21-00045  
Permitted Effluent Limitation Violations

Dear Mayor Simon,,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 1 violation of Part I, Section A of NPDES Permit No. AR0033987 during the review period. DEQ requires the City of Dumas to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at [gavin.gray@adeq.state.ar.us](mailto:gavin.gray@adeq.state.ar.us).

Sincerely,



Gavin Gray  
Enforcement Analyst  
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code
05/31/2020	001-A	Chlorine, total residual, INST MAX, mg/L	<0.028	<u>0.31</u>	1,007%	E90