



# ARKANSAS

## ENERGY & ENVIRONMENT

May 14, 2021

Honorable Flora J. Simon, Mayor  
City of Dumas  
155 E. Waterman  
Dumas, AR 71639

RE: NPDES Permit Number AR0033987, AFIN 21-00045  
Permitted Effluent Limitation Violations

Dear Mayor Simon,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 1 violation of Part I, Section A of NPDES Permit No. AR0033987 during the review period. DEQ requires the City of Dumas to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at [gavin.gray@adeq.state.ar.us](mailto:gavin.gray@adeq.state.ar.us).

Sincerely,

A handwritten signature in blue ink that reads "Gavin Gray".

Gavin Gray  
Enforcement Analyst  
Office of Water Quality, Enforcement Branch

**DMR Effluent Violations 03/01/2021 - 05/14/2021**

**AR0033987 - DUMAS, CITY OF / Major POTW - Effective: 02/01/2017**

DMR End Date	Discharge Number	Parameter Description	DMR Value Qualifier Code	Reported DMR Value	Permit Limit	Vio %	Violation Type	DMR Value Type Code	Parameter-Mon. Location-Season
03/31/2021	001-A	Chlorine, total residual (INST MAX, mg/L)	=	0.07	.028	150%	Numeric Vio	C3	50060-1-0