



ARKANSAS ENERGY & ENVIRONMENT

August 23, 2023

Honorable Price Boney, Mayor
City of Dumas
P.O. Box 157
Dumas, AR 71639

email: dumasarmayor@gmail.com

**RE: Permit Number: AR0033987, AFIN: 21-00045
Effluent Violation Warning Letter and Request for Non-Compliance Report**

Dear Mayor Boney:

A review of the Permit file for the above mentioned facility for the period of March 1, 2023 through June 30, 2023 reveals the following compliance issues:

The facility has reported **3 effluent violations** of Part I, Section A of Permit No. AR0033987:

AR0033987 - DUMAS, CITY OF (21-00045)

DMR End Date	Disch-Desig	Parameter Desc	Reported DMR Value	Limit Value	Vio %	Vio Code
03/31/2023	001-A	Chlorine, total residual (INST MAX, mg/L)	0.04	.028	43%	Numeric Vio
04/30/2023	001-A	Chlorine, total residual (INST MAX, mg/L)	0.03	.028	7%	Numeric Vio
06/30/2023	001-A	Chlorine, total residual (INST MAX, mg/L)	0.28	.028	900%	Numeric Vio

Non-compliance reports with corrective actions were received by the Division for the months of March and April 2023. The following Non-Compliance Reports (NCRs) is missing and must be submitted by August 28, 2023.

- June 001-A, for Total Residual Chlorine

Any violation of your Permit is subject to further enforcement action by this Division, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0736, or you may e-mail me at thomas.harrington@adeq.state.ar.us.

Sincerely,

A handwritten signature in blue ink that reads "Thomas Harrington". The signature is written in a cursive style with a long horizontal stroke at the beginning.

Thomas Harrington
Enforcement Analyst, DEQ, OWQ
5301 Northshore Drive, North Little Rock, AR 72118

cc: Patrick Fitzgerald, Water Manager, pfitz2003@yahoo.com