

ADEQ

ARKANSAS
Department of Environmental Quality

January 15, 2019

Hon. Jimmy Brigham, Mayor
City of Dumas
155 E. Waterman
Dumas, AR 71639

RE: NPDES Permit Number AR0033987, AFIN 21-00045
Permitted Effluent Limitation Violations

Dear Mayor. Brigham,

A review of recent Discharge Monitoring Reports (DMRs) for the above-mentioned facility revealed the following compliance issues:

The facility has reported 1 violation of Part I, Section A of NPDES Permit No. AR0033987 during the review period. A detailed list of the violation has been included with this letter. The Department expects the City of Dumas to work toward preventing violations of the Part I, Section A., Effluent Limitations and Monitoring Requirements of the Permit.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Should you have any questions concerning the above referenced compliance issues, please feel free to contact me at 501-682-0667, or you may e-mail me at gavin.gray@adeq.state.ar.us.

Sincerely,



Gavin Gray
Enforcement Analyst
Office of Water Quality, Enforcement Branch

Monitoring Period End Date	Dsch#	Parameter	Limit Value	DMR Value	% Vio	Violation Code
11/30/2018	001-A	Chlorine, total residual, INST MAX, mg/L	<0.028	0.1	257%	E90