

FEB 20/2019/WED 06:34 PM

FAX No

P. 102

### NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987 Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas State: AR Zip: 71639

Contact: Patrick Fitzgerald Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Instantaneous Maximum	Permit Limits
January 2nd, 2019	Total Residual Chlorine	0.05 mg/L	.028 mg/L Inst. Maximum

We feel this problem was due to:

*Flow sensor is bad*

We plan on correcting the problem in this manner:

*Running on manual feed at the moment*

Time estimated that it will take to correct the problem/s:

*talk with investment supply, unknown but within 2-4 weeks*

Sincerely,

*Patrick Fitzgerald*  
Authorized Signature

*2-21-19*  
Date