

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987 Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Instantaneous Maximum	Permit Limits
March 20th, 2019	Total Residual Chlorine	0.03 mg/L	.028 mg/L Inst. Maximum

We feel this problem was due to:

Facility monitors

We plan on correcting the problem in this manner:

New Equipment on Order

Time estimated that it will take to correct the problem/s:

1-2 month

Sincerely,

Patrick Fitzgerald
Authorized Signature

4-25-19
Date