

NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 8/01/2017 - 8/31/2017

FROM: City of Dumas-WWTP
204 Ford Loop Road
Dumas, AR 71639

DATE: 9/20/2017

PERMIT #: AR0033987

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Total Residual Chlorine exceeded the Instantaneous Max permit limit one time in August.

3. CAUSE FOR NON-COMPLIANCE:

Dilution Need adjusting

4. DURATION OF NON-COMPLIANCE:

The non compliance description above took place on August 3rd, 2017.

5. CORRECTIVE ACTION BEING TAKEN:

SIGNATURE: *Patrick Fitzgerald*