

Sheet1

Sheet2

Sheet3

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987

Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Instantaneous Maximum	Permit Limits
August, 2022	Total Residual Chlorine	0.4 mg/L	.028 mg/L Inst. Max limit
August, 2022	pH	9.5 units	9.0 Max limit

We feel this problem was due to:

Not sure, but checked the Automated Filter, made some adjustments.

We plan on correcting the problem in this manner:

Adjustments on filters

Time estimated that it will take to correct the problem/s:

1 Today

Sincerely,

Patrick Fitzgerald
Authorized Signature

12-9-2022

Date