

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987      Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas      State: AR      Zip: 71639

Contact: Patrick Fitzgerald      Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
8/30/23	Total Residual Chlorine	0.10 mg/L	0.028 mg/l Max limit

We feel this problem was due to:  
Uncertain

We plan on correcting the problem in this manner:  
Still checking a few things, basically, think auto feeder not working properly will run manually and check to see if that works

Time estimated that it will take to correct the problem/s:  
9-26-23

Sincerely,  
Patrick Fitzgerald  
Authorized Signature

9/26/23  
Date