

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987 **Discharge Number:** A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
December, 2022	Total Residual Chlorine	0.14 mg/L	0.028 mg/l Max limit
			mg/l/100ml 7D GEO

We feel this problem was due to:

CO2 Feeder not working

We plan on correcting the problem in this manner:

Run manually

Time estimated that it will take to correct the problem/s:

Same day

Sincerely,

Patrick Fitzgerald

11-2-23

Authorized Signature

Date