

NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 2/01/2017 - 2/28/2017

FROM: City of Dumas-WWTP
204 Ford Loop Road
Dumas, AR 71639

DATE: 3/24/2017

PERMIT #: AR0033987

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Total Residual Chlorine exceeded the INST MAX permit limit each time the samples were collected.

3. CAUSE FOR NON-COMPLIANCE:

Adjustment not properly made

4. DURATION OF NON-COMPLIANCE:

The Total Residual Chlorine violations took place between Feb. 1st-28th, 2017.

5. CORRECTIVE ACTION BEING TAKEN:

Made proper adjustment

SIGNATURE: *Patrick Fitzgerald*

NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 2/01/2017 - 2/28/2017

FROM: City of Dumas-WWTP
204 Ford Loop Road
Dumas, AR 71639

DATE: 3/24/2017

PERMIT #: AR0033987

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Total Residual Chlorine exceeded the INST MAX permit limit each time the samples were collected.

3. CAUSE FOR NON-COMPLIANCE:

Adjustment not properly made

4. DURATION OF NON-COMPLIANCE:

The Total Residual Chlorine violations took place between Feb. 1st-28th, 2017.

5. CORRECTIVE ACTION BEING TAKEN:

Made proper adjustment

SIGNATURE: *Patrick Fitzgerald*