

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987 Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas State: AR Zip: 71639

Contact: Patrick Fitzgerald Phone: 870-382-1143

| Date of Non-Compliance | Parameter Exceeded | Quality or Concentration | Permit Limits |
|------------------------|-------------------------|--------------------------|----------------------|
| Jun-23 | Total Residual Chlorine | 0.28 mg/L | 0.028 mg/l Max limit |
| Jun-23 | Fecal | 820#/100mL 7D GEO | 400#/100mL 7D GEO |

We feel this problem was due to: SN The TRC ~~2020~~ SO2 Bottle empty
Not sure may have been a floater

We plan on correcting the problem in this manner:
Change BOTTLE OF SO2

Time estimated that it will take to correct the problem/s:
11-8-23

Sincerely,
Patrick Fitzgerald
Authorized Signature

11-7-23
Date