

NON-COMPLIANCE NOTIFICATION

DMR Monitoring Period 3/01/2017 - 3/31/2017

FROM: City of Dumas-WWTP
204 Ford Loop Road
Dumas, AR 71639

DATE: 4/20/2017

PERMIT #: AR0033987

TO: NPDES Enforcement
ADEQ
5301 Northshore Drive
North Little Rock, AR 72118

1. DISCHARGE DESCRIPTION 001

2. NON-COMPLIANCE DESCRIPTION:

The Total Residual Chlorine exceeded the INST MAX permit limit eleven times during the month of IV

3. CAUSE FOR NON-COMPLIANCE:

*Leak in Sulphon line leading
to contact Chamber*

4. DURATION OF NON-COMPLIANCE:

The Total Residual Chlorine violations took place between March 1st and March 23rd.

5. CORRECTIVE ACTION BEING TAKEN:

Repaired leaking line

SIGNATURE:

Patrick Fitzgerald