

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987 Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
November, 2022	Total Residual Chlorine	0.14 mg/L	0.028 mg/l Max limit

We feel this problem was due to:

Chemical Feeder not working properly

We plan on correcting the problem in this manner:

Take OFF Auto & run manual dose until get Feeder fixed or replace

Time estimated that it will take to correct the problem/s:

Not sure about Feeder but will switch to manual - today

Sincerely,

Patrick Fitzgerald
Authorized Signature

12/15/22
Date