

# NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality  
NPDES Enforcement Section  
5301 Northshore Drive  
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987      Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
9/20/23	Total Residual Chlorine	0.06 mg/L	0.028 mg/l Max limit

We feel this problem was due to:

*Auto Feeder*

We plan on correcting the problem in this manner:

*Running manually*

Time estimated that it will take to correct the problem/s:

*10-1-23*

Sincerely,

*Patrick Fitzgerald*

Authorized Signature

*11-7-23*

Date