

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033087 Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Instantaneous Maximum	Permit Limits
August 31st, 2021	Total Residual Chlorine	0.06 mg/L	.028 mg/L Inst. Maximum

We feel this problem was due to:

Not sure but perhaps the sulfur Dues

We plan on correcting the problem in this manner:

Adjust the sulfur Feed

Time estimated that it will take to correct the problem/s:

Today

Sincerely,

Patrick Fitzgerald
Authorized Signature

9-28-21
Date