

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987

Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

| Date of Non-Compliance | Parameter Exceeded | Instantaneous Maximum | Permit Limits |
|------------------------|-------------------------|-----------------------|-------------------------------|
| September, 2022 | Total Residual Chlorine | 0.09 mg/L | .023 mg/L Inst. Maximum limit |
| | | | |
| | | | |

We feel this problem was due to:

not sure

We plan on correcting the problem in this manner:

adjusting the sulfur flow

Time estimated that it will take to correct the problem/s:

Immediately

Sincerely,

Patrick Fitzgerald

Authorized Signature

Date

10-19-2022