

March 19, 2015

CERTIFIED MAIL: 91 7199 9991 7030 4937 5862

Honorable Johnny Brigham c/o Patrick Fitzgerald City of Dumas 155 E. Waterman Dumas, AR 71639

RE: NPDES Permit No. AR0033987, AFIN: 21-00045

NPDES Permit Effluent Violations, Missing Discharge Monitoring Reports, and

CAP Request

Dear Mayor Brigham:

The Department has conducted a file review of the above referenced permit and determined your facility reported eleven (11) effluent violations of Part I, Section A of your Permit from December 1, 2011 through January 31, 2015. Attached is a detailed list.

The Department has also determined that the Discharge Monitoring Reports (DMRs) for monitoring period ending 08/31/2014, Discharge Number <u>001-A</u>, and monitoring period ending 12/31/2014, Discharge Number <u>TX1-Q</u>, are not on file. Failure to submit DMRs is a violation of Part II, Section C.5 of your Permit.

The Department recommends that you consult with a Professional Engineer for the purpose of developing a Corrective Action Plan (CAP). The CAP should detail the corrective actions taken or that will be taken to achieve compliance with the terms of the Permit. The CAP should <u>include the date the Facility expects to be in compliance</u>. Please submit the CAP to the Department by **April 2, 2015**.

Any violation of your NPDES Permit is subject to enforcement action by this Department, pursuant to the Arkansas Water and Air Pollution Control Act. The regulations and your NPDES Permit require that you take all reasonable measures necessary to eliminate or prevent the occurrence of violations.

Lastly, the Department has not received an updated signatory authorization form for the facility, and Mayor James Berry is still listed as the facility's Responsible Official. Enclosed is a signatory authorization form. Please fill out the form completely and submit the completed form back to the Department.

Thank you for your attention to this matter. Should you have any questions, feel free to contact me at 501-682-0823 or you may e-mail me at barber@adeq.state.ar.us.

Honorable Johnny Brigham c/o Patrick Fitzgerald City of Dumas

AR0033987, AFIN: 21-00045 Page **2** of **3** March 9, 2015

Sincerely,

Kyle Barber

Enforcement Analyst

Water Division, Enforcement Branch

AR0033987, AFIN: 21-00045 Page **3** of **3** March 9, 2015

3/19/2015

DMR Violations for AR0033987 Since 12/1/11

AR0033987 - DUMAS, CITY OF (21-00045)

DMR End Date	Disch- Desig	Parameter Desc	Reported DMR Value	Limit Value
08/31/2012	001-A	pH (MAXIMUM, SU)	9.4	9
09/30/2012	001-A	pH (MAXIMUM, SU)	9.91	9
10/31/2012	001-A	pH (MAXIMUM, SU)	9.81	9
07/31/2013	001-A	pH (MAXIMUM, SU)	9.29	9
09/30/2013	001-A	pH (MAXIMUM, SU)	9.03	9
01/31/2014	001-A	Chlorine, total residual (INST MAX, mg/L)	0.1	.1
02/28/2014	001-A	Chlorine, total residual (INST MAX, mg/L)	0.1	.1
06/30/2014	001-A	Chlorine, total residual (INST MAX, mg/L)	0.4	.1
07/31/2014	001-A	Chlorine, total residual (INST MAX, mg/L)	0.2	.1
09/30/2014	001-A	Chlorine, total residual (INST MAX, mg/L)	0.2	.1
10/31/2014	001-A	Chlorine, total residual (INST MAX, mg/L)	0.15	.1