

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987

Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Instantaneous Maximum	Permit Limits
October 9th-11th, 2018	Total Residual Chlorine	0.25 mg/L (Oct. 9th), 0.03 (10th), 0.13 (11th)	.028 mg/L Inst. Maximum

We feel this problem was due to:

We plan on correcting the problem in this manner:

Time estimated that it will take to correct the problem/s:

Sincerely,

Patrick Fitzgerald
Authorized Signature

11-16-18
Date