

NON-COMPLIANCE REPORT

Arkansas Department of Environmental Quality
NPDES Enforcement Section
5301 Northshore Drive
North Little Rock, AR 72118

RE: NPDES Permit No: AR0033987 Discharge Number: A - 001-Monthly

Facility: The City of Dumas

Address: 204 Ford Loop Road

City: Dumas

State: AR

Zip: 71639

Contact: Patrick Fitzgerald

Phone: 870-382-1143

Date of Non-Compliance	Parameter Exceeded	Quality or Concentration	Permit Limits
Oct-23	Total Residual Chlorine	0.25 mg/L	0.028 mg/l Max limit
Oct-23	Fecal	>2420#/100mL 7D GEO	2000#/100mL 7D GEO

We feel this problem was due to:

Aeration still need of Repair

Sulfur Needed changing

We plan on correcting the problem in this manner:

Repair Aeration lines

Replace Sulfur bottles

Time estimated that it will take to correct the problem/s:

Repair soon as possible contracted out

Same day Replace Sulfur

Sincerely,

Patrick Fitzgerald

Authorized Signature

11-20-23

Date